TÜVRheinland® DIN CERTCO

Fraunhofer ISE

| Summary of EN 12975 Test Results, annex to Solar KEYMARK Certificate | Licence number | 011-7S1785 F |
|---|---|---|
| | Date of issue | 03.05.2012 |

| | | | |
|---|---|---|---|
| **Company** holding the licence | COSMO GmbH | **Country** | Germany |
| **Brand** (optional) | | **Website** | |
| **Street, number** | Brandstücken 31 | **E-mail** | info@cosmo-info.de |
| **Postal Code** | 22549 | **Tel.** | +40 (0)40 80030430 |
| **City** | Hamburg | **Fax** | |

| | |
|---|---|
| **Collector Type** (flat plate / evacuate tubular / un-glazed) | Flat plate collector |
| **Integration in the roof possible ?** | No |

| Collector name | Aperture area (Aa) [m²] | Gross length [mm] | Gross width [mm] | Gross height [mm] | Gross area (AG) [m²] | Power output per collector unit G = 1000 W/m² Tm-Ta : 0 K [W] | 10 K [W] | 30 K [W] | 50 K [W] | 70 K [W] |
|---|---|---|---|---|---|---|---|---|---|---|
| COSMO 251RK | 2,295 | 2.150 | 1.170 | 83 | 2,52 | 1.864 | 1.774 | 1.577 | 1.357 | 1.112 |
| COSMO 251RKW | 2,295 | 2.150 | 1.170 | 83 | 2,52 | 1.864 | 1.774 | 1.577 | 1.357 | 1.112 |

| | | | |
|---|---|---|---|
| **Collector efficiency parameters related to aperture area (Aa)** Type of fluid and flow rate see note 1 | $\eta_{0a}$ | 0,812 | - |
| | $a_{1a}$ | 3,763 | W/(m²K) |
| | $a_{2a}$ | 0,0131 | W/(m²K²) |
| **Stagnation temperature** - Weather conditions see note 2 | $t_{stg}$ | 189 | °C |
| **Effective thermal capacity** | $c_{eff} = C/A_a$ | 4,47 | kJ/(m²K) |
| **Max. operation pressure - see note 3** | $p_{max}$ | 10 bar | kPa |

| Incidence angle modifiers $K_\theta(\theta)$ | $G_{DIF}/G_{TOT}$ min | $G_{DIF}/G_{TOT}$ max | $\theta_T$ / $\theta_L$ | 50° | *10°* | *20°* | *30°* | *40°* | *60°* | *70°* |
|---|---|---|---|---|---|---|---|---|---|---|
| | | | $K_\theta(\theta_T)$ | 0,96 | *1,00* | *1,00* | *1,00* | *0,99* | *0,90* | *0,78* |
| | 0,152 | 0,206 | $K_\theta(\theta_L)$ | 0,96 | *1,00* | *1,00* | *1,00* | *0,99* | *0,90* | *0,78* |
| $G_{DIF}/G_{TOT}$: min&max - while measuring | | | | | ***Optional values*** | | | | | |

| | |
|---|---|
| **Testing Laboratory** | Fraunhofer ISE, TestLab Solar Thermal Systems, |
| **Website** | www.kollektortest.de |
| **Test report id. number** | ktb-2012-01-a; ktb2012-02-a |
| **Date of test report** | 03.05.2012 |
| **Perf. test method** | EN 12975-2 6.1.5 (indoor) |

**Comments of testing laboratory** :

| | | | | | |
|---|---|---|---|---|---|
| Note 1 | **Fluid** | Water | **Flow rate** | 0,020 | kg/s per m² |
| Note 2 | **Irradiance, Gs=1000 W/m²; Ambient temperature , Ta=30 °C** | | | | |
| Note 3 | **Given by manufacturer** | | | | |

TestLab Solar Thermal Systems
Heidenhofstraße 2
D-79110 Freiburg
Tel: +49 (0)761 4588 5354

VERSION 3.7, 2012.03.22

| Annual collector output based on EN 12975 Test Results, annex to Solar KEYMARK Certificate | Licence number | RRRRRRRRR |
|---|---|---|
| | Issued | dd-mm-yyyy |

**Annual collector output kWh**

| Collector name | Location and collector temperature (Tm) | | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Athens | | | Davos | | | Stockholm | | | Würzburg | | | | | |
| | 25°C | 50°C | 75°C | 25°C | 50°C | 75°C | 25°C | 50°C | 75°C | 25°C | 50°C | 75°C | | | |
| COSMO 251RK | 3.020 | 2.177 | 1.444 | 2.477 | 1.723 | 1.090 | 1.694 | 1.120 | 688 | 1.843 | 1.213 | 733 | | | |
| COSMO 251RKW | 3.020 | 2.177 | 1.444 | 2.477 | 1.723 | 1.090 | 1.694 | 1.120 | 688 | 1.843 | 1.213 | 733 | | | |

| Collector mounting: Fixed or tracking | No tracking; Slope = latitude - 15° (rounded to nearest 5°) |
|---|---|

**Overview of locations**

| Location | Latitude ° | Gtot kWh/m² | Ta °C | Collector orientation or tracking mode |
|---|---|---|---|---|
| Athens | 38 | 1.765 | 18,5 | South, 25° |
| Davos | 47 | 1.714 | 3,2 | South, 30° |
| Stockholm | 59 | 1.166 | 7,5 | South, 45° |
| Würzburg | 50 | 1.244 | 9,0 | South, 35° |

| | | |
|---|---|---|
| Gtot | Annual total irradiation on collector plane | kWh/m² |
| Ta | Mean annual ambient air temperature | °C |
| Tm | Constant collector operating temperature (mean of in- and outlet temperatures) | °C |

Calculation of the annual collector performance is done by the official Solar Keymark spreadsheet tool. Hour by hour the collector output is calculated according to the efficiency parameters from the Keymark test using constant collector operating temperature (Tm). Detailed description with all equations used is available from the Solar Keymark web site (direct link: http://www.estif.org/solarkeymark/annexb1.php)

**CERTIFICATION BODY FOOTERDIN CERTCO ● Alboinstraße 56 ● 12103 Berlin**
**Tel: +49 30 7562-1131 ● Fax: +49 30 7562-1141 ● E-Mail: info@dincertco.de ● www.dincertco.de**

Datasheet version:
VERSION 3.7, 2012.03.22
Calculation program version:
3.07, October 2011 (SP)